



# ADMINISTRATIVE OFFICE OF THE COURTS

GOVERNMENT RELATIONS  
INFORMATION TECHNOLOGY  
INTERNAL AFFAIRS  
JUDICIAL COLLEGE OF MARYLAND  
**OPERATIONS**  
PROGRAMS

## Questions/Responses No. 1 to the Request for Proposals (RFP) K17-0033-25 Judicial Center Parking Lot Asphalt Paving Repairs

Ladies and Gentlemen:

The following questions for the above referenced RFP were received by the procurement officer and are answered and posted for all prospective Offerors. The statements and interpretations contained in the following responses to questions are not binding on the Maryland Judiciary unless the RFP is expressly amended. Nothing in the Maryland Judiciary's response to these questions is to be construed as agreement to or acceptance by the Maryland Judiciary of any statement or interpretation on the part of the Offeror asking the question.

Questions for Parking Lot J.

- Questions:** What would be the hours of operation?  
**Response:** **All work shall be accomplished overnight after 6:00 P.M and before 6:00 A.M.**
- Question:** Are their site drawing of the parking lots?  
**Response:** **No, we do not have site drawings to provide.**
- Question:** How many inches requested?  
**Response:** **Overlay the existing parking lot with 2"-3" of new surface course asphalt.**
- Question:** Are the parking lots marked, Can we re-measure each lot?  
**Response:** **Yes, each lot is outline with white markings. Yes, Attendees have permission to re-measure.**
- Question:** Are testing specs required?  
**Response:** **No, not needed.**

6. **Question:** May need undercut with stones sitting on truck or stones sitting on site. Will we receive payment for that?  
**Response:** Yes, the price proposal sheet will be amended to include for such expenses. We can also provide storage of the stone at DGS.
7. **Question:** Will pro-rolling be required?  
**Response:** Yes, pro-rolling before milling and pro-rolling subgrade repairs. No pumping required as it rolls across the subgrade.
8. **Question:** What type of new surface course shall be used?  
**Response:** Asphalt for the new surface course shall be Hot Mix Asphalt Superpave 9.5mm, PG 64-22, Level 2, or approved equal.

Questions for Parking Lot K.

1. **Questions:** Is there Sound Ordinance?  
**Response:** Sound Ordinance does not apply to us as we are State property. We are exempt from this rule.
2. **Question:** Can work be performed on Saturday?  
**Response:** No, we are asking for the work to be performed during the weekdays, overnight after 6:00 P.M and before 6:00 A.M. An addendum will be created to adjust section 2.3.3 on the RFP.
3. **Question:** Will the price proposal sheet be amended?  
**Response:** Yes, it will be amended to include pricing for the 2-3 inch Subgrade Base Course as per sq. yard<sup>2</sup> inch in life of Subgrade.

Issued by: April Molley  
Procurement Officer  
October 6, 2016