



ADMINISTRATIVE OFFICE OF THE COURTS
MARYLAND JUDICIAL CENTER
580 TAYLOR AVENUE
ANNAPOLIS, MARYLAND 21401

June 3, 2009

FRANK BROCCOLINA
STATE COURT ADMINISTRATOR
(410) 260-1295 Fax: (410) 974-2066
frank.broccolina@mdcourts.gov

FAYE D. GASKIN
DEPUTY STATE COURT
ADMINISTRATOR
(410) 260-1257 Fax: (410) 974-2066
faye.gaskin@mdcourts.gov

SHARON SAMPSON BALL
Executive Director
Human Resources
(410) 260-1283 Fax: (410) 974-2849
sharon.ball@mdcourts.gov

GRAY BARTON
Executive Director
Office of Problem-Solving Courts
2011-D Commerce Park Drive
Annapolis, Maryland 21401
(410) 260-3617 Fax: (410) 841-9850
gray.barton@mdcourts.gov

PHILIP S. BRAXTON
Executive Director
Judicial Information Systems
2661 Riva Road, Suite 900
Annapolis, Maryland 21401
(410) 260-1000 Fax: (410) 974-7170
philip.braxton@mdcourts.gov

ALLEN C. CLARK, III
Executive Director
Budget & Finance
(410) 260-1579 Fax: (410) 260-1290
allen.clark@mdcourts.gov

DAVID R. DURFEE JR.
Executive Director
Legal Affairs
(410) 260-1405 Fax: (410) 974-2066
david.durfee@mdcourts.gov

RAYMOND MACK
Executive Director
Procurement & Contract
Administration
(410) 260-1410 Fax: (410) 260-1749
raymond.mack@mdcourts.gov

Connie Kratovil-Lavelle
Executive Director
Family Administration
(410) 260-1580 Fax: (410) 974-5577
pamela.ortiz@mdcourts.gov

DIANE S. PAWLOWICZ
Executive Director
Court Research & Development
(410) 260-1725 Fax: (410) 974-2066
diane.pawlowicz@mdcourts.gov

ROXANNE P. MCKAGAN
Manager
Administrative Services
(410) 260-1407 Fax: (410) 974-2066
rocky.mckagan@mdcourts.gov

DEBORAH A. UNITUS
Manager
Program Services
(410) 260-1291 Fax: (410) 974-5577
deborah.unitus@mdcourts.gov

Re: Request for Proposals K09-9115-26J
Audio Video Equipment
Thomson Grass Valley Routing Switcher

AMENDMENT # 4

Dear Interested Party:

The Administrative Office of the Courts (AOC) hereby makes the following clarifications/changes to the above referenced Request for Proposals.

The following consists of questions raised by potential bidders on the above referenced solicitation and the AOC's responses.

Q1. Is the space above the ceiling - Plenum?

A1. The ceiling space above is plenum

Q2.WPS assumes at this point that plenum-rated cable will fulfill the code requirements.

A2. Plenum rated cable satisfies the NEC code requirement

Q3.Will the installation of the cable require low voltage permits? If so, is the issuing authority the City of Annapolis or the County?

A3.Low voltage permits required. The County is issuing authority permits.

Thank you for your interest in doing business with the Maryland Judiciary.

Sincerely,

Karen Hoang
Procurement Specialist